

Asbestos Register To be kept Onsite

Property : Sample Apartments , 2-6 Glen Court , Brisbane

Built : 1973

Inspected : 17-11-2011

Laboratory Report : Asbestos Identified Lab Report Attached

Inspection Areas

Location	Friable/Bonded	Condition	Asbestos Type
Driveway Area	NA	NA	NA
Date Inspected	Inspector	Asbestos Detected	Details
17/12/2011	SL	None	

Location	Friable/Bonded	Condition	Asbestos Type
Main Building Soffits	NA	NA	NA
Date Inspected	Inspector	Asbestos Detected	Details
17/12/2011	SL	Not Suspected	

Location	Friable/Bonded	Condition	Asbestos Type
Roof Area	Bonded	Tightly Bound	Chrrysotile
Date Inspected	Inspector	Asbestos Detected	Details
17 -12- 2011	SL	Yes, Roof sheeting and Barge Board	

External Accessways	Friable/Bonded	Condition	Asbestos Type
Boundary Area	NA	NA	NA
Date Inspected	Inspector	Asbestos Detected	Details
17/12/2011	SL	None	



Location	Friable/Bonded	Condition	Asbestos Type
Switchboard Box	NA	NA	NA
Date Inspected	Inspector	Asbestos Detected	Details
17/12/2011	SL	No Asbestos	Identified

Location	Friable/Bonded	Condition	Asbestos Type
Boundary Area	NA	NA	NA
Date Inspected	Inspector	Asbestos Detected	Details
17/12/2011	SL	None	

Location	Friable/Bonded	Condition	Asbestos Type
Amenities	NA	NA	NA
Date Inspected	Inspector	Asbestos Detected	Details
17/12/2011	SL	None	

Suspected inaccessible areas

Locations



Recommended Signage To Be Installed



